



Certificate of Compliance

This Certifies that

100mm Polyester Filtersock

Used by Cromford Pipe
Conforms to:

RMS:3553 – Seamless Tubular Filter Fabric

Test	Name	Result	
RMS T1520-2012	Determination of Yield Seamless Knitted Tubular Filter Fabric	√	Pass
RMS T1521-2012	Laddering, Unravelling, or Deweaving of a Seamless Knitted Tubular Filter Fabric from a Cut End	√	Pass
RMS T1522-2012	Abrasion Resistance of Seamless Knitted Tubular Filter Fabric	√	Pass
RMS T1523-2012	Weave Stability of Seamless Knitted Tubular Filter Fabric	√	Pass
AS 3706.7-2014	Determination of Pore-Size Distribution – Dry-sieving Method	√	Pass

Results recorded from NATA certified AWT. Test #23-000849 12/4/2023

Material – 100% Polyester (non-recycled)

Terry Hammerton
Production Manager
Cromford Pipe Holdings

4/5/2023



Certificate of Compliance

This Certifies that

100mm SN8 (Class 400) Flexi pipe

Manufactured by Cromford Pipe
Conforms to:

Specifications	AS 2439	Test Method	Requirement	Result	
Freedom from defects	2.3	Visual inspection	Clause 2.3.1	√	Pass
Diameter	2.4.1	Appendix B	Within OD range of 99.0mm & 102.0mm	√	Pass
Length	2.4.2	Measurement	Clause 2.4.2	√	Pass
Physical Properties	3.1	Appendix B	Slot range 3 > <10 with minimum 1500mm ² /LM	√	Pass
Stiffness Properties	5.7	AS/NZS 1462.22	>8000 @ 5% Deflection >6400 @10% Deflection	√	Pass

Using test methods specified in:

AS 2439.1 Perforated Drainage Pipe and Associated Fittings, Part 1 2007

Pipe Details: SN8 (Class 400) HD 100mm Corrugated & Perforated

Production Date: July-2019

Batch No's: 07-2019-100HD

Material: HDPE

A blue ink signature of Terry Hammerton.

Terry Hammerton
QA Coordinator

10/07/2019